



Sample ID No.: SCS/W/20260318/02	Date of Registration: 18.03.2026
Report No. SCS/RSWM-RSD/W/20260318/02(1/2)	Date of Report: 23.03.2026

TEST REPORT

Name of Client : M/s. RSWM Limited,
Address of Client : Unit: Rishabdev, Post: Rishabdev, Udaipur
Date of Sample Receipt : 18.03.2026
Date of start of testing : 19.03.2026
Date of end of testing : 23.03.2026
Details of Sample : RO Drinking Water from Vivekananda Kendra Vidyalaya, Rishabdev
Sample collected by : Industry Representative

Parameter	Results	IS - 10500:2012		Protocol
		Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source	
Table 1: Organoleptic and Physical Parameters				
Color, Hazen Units	< 1	5	15	APHA (24 th Edition) 2120B
Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 7)
Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5)
pH	7.15	6.5 - 8.5	No Relaxation	APHA (24 th Edition) 4500 H
Turbidity, NTU	< 0.1	1	5	APHA (24 th Edition) 2130
Total Dissolved Solids	135.00 Mg / L	500 Mg / L	2,000 Mg / L	APHA (24 th Edition) 2540 C
Table 2: General Parameters Concerning Substances Undesirable in Excess Amounts				
Calcium as Ca	12.80 Mg / L	75 Mg / L	200 Mg / L	APHA (24 th Edition) 3500 Ca B
Chloride as Cl	21.99 Mg / L	250 Mg / L	1,000 Mg / L	APHA (24 th Edition) 4500 Cl B
Fluoride as F	0.18 Mg / L	1.0 Mg / L	1.5 Mg / L	APHA (24 th Edition) 3111 B
Free Residual Chlorine	< 0.1 Mg / L	0.2 Mg / L	1.0 Mg / L	APHA (24 th Edition) 4500 F D
Iron as Fe	< 0.01 Mg / L	0.3 Mg / L	No Relaxation	APHA (24 th Edition) 4500 B
Magnesium as Mg	6.80 Mg / L	30 Mg / L	100 Mg / L	APHA (24 th Edition) 3111 B
Manganese as Mn	< 0.01 Mg / L	0.1 Mg / L	0.3 Mg / L	APHA (24 th Edition) 3500 Mg B
Nitrate as NO ₃	10.62 Mg / L	45 Mg / L	No relaxation	APHA (24 th Edition) 3111 B
Sulphate as SO ₄	< 5.00 Mg / L	200 Mg / L	400 Mg / L	APHA (24 th Edition) 4500 B
Total Alkalinity as CaCO ₃	64.00 Mg / L	200 Mg / L	600 Mg / L	APHA (24 th Edition) 4500 E
Total Hardness as CaCO ₃	60.00 Mg / L	200 Mg / L	600 Mg / L	APHA (24 th Edition) 2320

Per pro SCS Enviro Services Pvt. Ltd.,


Dr. D. S. Parihar
(Technical Manager)
Authorised Signatory



- The results refer only to the tested sample and applicable parameters.
- This report in full or in part, shall not be used for advertising or as evidence in any court of law.
- This report cannot be reproduced without the written permission of the director.
- The sample will be destroyed after 15 days from the date of issue of the test report.
- The liability of the laboratory is limited to the invoiced amount.
- All disputes are subjected to Jaipur jurisdiction.

SCS SCS ENVIRO SERVICES PRIVATE LIMITED

7, KESAR VIHAR, OPPOSITE KHATU SHYAMJI TEMPLE,
RAMNAGARIYA ROAD, JAGATPURA,
JAIPUR-302017, RAJASTHAN (INDIA)
CIN NO.: U74140RJ2013PTC042216

ISO-9001:2015 CERTIFIED LABORATORY
ISO-14001:2015 CERTIFIED LABORATORY
ISO-45001:2018 CERTIFIED LABORATORY


Sample ID No.: SCS/W/20260318/02	Date of Registration: 18.03.2026
Report No. SCS/ RSWM-RSD/W/20260318/02(2/2)	Date of Report: 23.03.2026

TEST REPORT

Name of Client : M/s. RSWM Limited,
Address of Client : Unit: Rishabdev, Post: Rishabdev, Udaipur
Date of Sample Receipt : 18.03.2026
Date of start of testing : 19.03.2026
Date of end of testing : 23.03.2026
Details of Sample : RO Drinking Water from Vivekananda Kendra Vidyalaya, Rishabdev
Sample collected by : Industry Representative

Parameter	Results	IS – 10500:2012		Protocol
		Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source	
Bacteriological Quality of Drinking Water				
E. Coli	Absent	Shall not be detectable in any 100 ml sample		IS: 15185
Total Coliform	Absent	Shall not be detectable in any 100 ml sample		IS: 15185

Per pro SCS Enviro Services Pvt. Ltd.,


Dr. D. S. Parihar
(Technical Manager)
Authorised Signatory



- The results refer only to the tested sample and applicable parameters.
- This report in full or in part, shall not be used for advertising or as evidence in any court of law.
- This report cannot be reproduced without the written permission of the director.
- The sample will be destroyed after 15 days from the date of issue of the test report.
- The liability of the laboratory is limited to the invoiced amount.
- All disputes are subjected to Jaipur jurisdiction.